

Application No. OH0126268

Issue Date: May 13, 2014

Effective Date: June 1, 2014

Expiration Date: May 31, 2019

Ohio Environmental Protection Agency
Authorization to Discharge Under the
National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

Village of Lisbon

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA", to discharge from the combined sewer overflows located within the Village of Lisbon service area along Little Beaver Creek only during wet weather periods when flows exceed the capacity of the sewer system in accordance with the conditions specified in Parts I, II, and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Craig W. Butler
Director

Total Pages: 27

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034003, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling

Table - CSO Monitoring - 003 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034003:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. "See Part II, Item E for requirements on monitoring different CSO stations."
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034004, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 004 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units				Loading* kg/day		Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034004:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034005, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 005 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034005:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034006, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 006 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units				Loading* kg/day		Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034006:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034009, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 009 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034009:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034011, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 011 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units				Loading* kg/day		Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034011:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 3PA00034012, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - CSO Monitoring - 012 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All

NOTES for Station Number 3PA00034012:

- Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from this station only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- A Discharge Monitoring Report (DMR) for this station must be submitted every month. See Part II, Item E for requirements on monitoring different CSO stations.
- If this station is not monitored during a particular month: (1) Leave the data area blank; (2) Enter "Monitoring not required" in the Remarks section; and (3) PIN the eDMR.
- If this station is monitored during a particular month and there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- Data for Overflow Occurrence and Overflow Volume may be estimated if a measuring device is not available.
- Overflow Occurrences: If a discharge from this station occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.
- Overflow Volume shall be reported on each day there is a discharge through this station. Data for total suspended solids and CBOD shall be reported once per month.

Part I, C - Schedule of Compliance

Municipal Construction Schedule

A. Nine Minimum Controls Implementation

The permittee shall immediately implement the minimum control measures identified by U.S. EPA for CSOs that are applicable to its system:

1. The permittee shall implement proper operation and maintenance programs for the sewer system and all CSO outfalls to reduce the magnitude, frequency and duration of CSOs. The programs shall consider regular sewer inspections; sewer, catch basin and regulator cleaning; equipment and sewer collection system repair or replacement where necessary; and disconnection of illegal connections.
2. The permittee shall implement procedures that will maximize use of the collection system for wastewater storage to reduce the magnitude, frequency and duration of CSOs.
3. The permittee shall evaluate the CSO impacts from non-domestic users and take appropriate steps to minimize such impacts.
4. The permittee shall deliver all flows to the Elkton POTW within constraints of the treatment capacity of the Elkton POTW and within the constraints of all pump stations established to deliver flow from the village to the POTW.
5. Dry weather overflows from CSOs are prohibited. Each dry weather overflow must be reported to Ohio EPA, Northeast District Office as soon as the permittee becomes aware of the overflow. When the permittee detects a dry weather overflow, the permittee shall begin corrective actions immediately. The permittee shall halt the discharge as soon as possible. The permittee shall inspect the dry weather overflow each subsequent day until the overflow has been terminated.
6. The permittee shall implement measures to control solid and floatable materials in CSOs.
7. The permittee shall implement a pollution prevention program focused on reducing the impact of CSOs on receiving waters.
8. The permittee shall implement a public notification process to inform citizens when and where CSOs occur. The process must include (a) a mechanism to alert persons of the occurrence of CSOs and (b) a system to determine the nature and duration of conditions that are potentially harmful for users of receiving waters due to CSOs.
9. The permittee shall monitor CSO outfalls to characterize impacts and efficiency of CSO controls. This shall include data collection that will be used to document the existing baseline conditions and evaluate the efficiency of the technology based controls.

B. Combined Sewer Overflow Long-Term Control Plan Implementation Schedule

The permittee's "Long Term Control Plan for Combined Sewer Overflows" (final April 2008 and received on May 2, 2008) includes an acceptable implementation schedule for sewer separation projects with the goal of CSO elimination.

The permittee shall implement the "Long Term Control Plan for Combined Sewer Overflows" (final April 2008 and received on May 2, 2008) and approved by the Director on October 22, 2008 as Plan Approval Number 654980 as expeditiously as possible, but not later than the dates developed in accordance with the following schedule:

1. Within 3 months of the effective date of this permit, the permittee shall submit two copies of a report summarizing its combined sewer overflow (CSO) activations and volumes and CSO control activities during the previous permit cycle. One copy of the report shall be sent to the Ohio EPA, Division of Surface Water, P.O. Box 1049, Columbus, Ohio, 43216-1049; and one copy shall be sent to the Ohio EPA Northeast District Office. (Event Code 95999)
2. Complete construction of Project 7 Combined Sewer Separation (East Chestnut Street) allowing for elimination of CSO 3PA00034003 (#25003) not later than September 1, 2014.
3. Complete construction of Project 9 Combined Sewer Separation (Juvenile Center to Washington Street Connection) allowing for elimination of CSO 3PA00034009 (#25009) not later than September 1, 2015.

4. By December 31, 2015, the permittee shall submit two copies of a report (Project 8 Combined Sewer Separation) which includes the following:
- a. A characterization of volumes and number of occurrences for all CSO locations within the collection system,
 - b. A summary of the collection system improvements that have been constructed,
 - c. Identification of CSOs that are able to be physically eliminated as a result of separation work performed to date. Once the permittee has determined that a CSO can be physically eliminated, the permittee should move forward with physical elimination as expeditiously as possible
 - d. Recommendations for additional projects that will allow for the elimination of any remaining CSOs, should any exist,
 - e. Cost estimates for any additional projects proposed in accordance with Part I, C Item B.4.d,
 - f. The report shall propose a fixed date compliance schedule for any additional projects proposed in accordance with Part I, C Item B.4.d. The proposed compliance schedule shall result in construction of the additional projects as expeditiously as possible, but in no case shall the final implementation date extend beyond December 31, 2020.

One copy of the report shall be sent to the Ohio EPA, Division of Surface Water, P.O. Box 1049, Columbus, Ohio, 43216-1049; and one copy shall be sent to the Ohio EPA Northeast District Office.

5. Complete construction of Project 10 Combined Sewer Separation (Alley between Jefferson Street and Market Street) not later than September 1, 2016.
6. Complete construction of Project 12 Combined Sewer Separation (Performance of any projects identified in Project 8 Combined Sewer Separation) not later than December 31, 2020.

This NPDES permit, Ohio EPA permit number 3PA00034*CD-, expires on _____. This Schedule of Compliance includes items that extend beyond the term of the permit. The requirements of Schedule of Compliance Items B, 4 through B, 6 including the compliance dates, will be included in permit 3PA00034 when it is renewed.

Collection system improvement projects will require submission of a Permit to Install/Plan Approval Application, accompanied by detail plans, as required by the Ohio Revised Code Chapter 6111.44 and the Ohio Administrative Code Chapter 3745-31. Construction shall not be initiated until a permit to install, based upon the approval of detail plans, is obtained from Ohio EPA.

Including this implementation schedule in this NPDES permit shall in no way be construed as acceptance or approval of detail plans.

Part II, Other Requirements

A. Operator Certification Requirements

1. Classification

a. In accordance with Ohio Administrative Code 3745-7-04, the sewage system regulated under NPDES 3PA00034*CD is Class II.

2. The operator of record for a class II, III, or IV treatment works or class II sewerage system may be replaced by a backup operator with a certificate one classification lower than the treatment works or sewerage system for a period of up to thirty consecutive days. The use of this provision does not require notification to the agency.

3. Upon proper justification, such as military leave or long term illness, the director may authorize the replacement of the operator of record for a class II, III, or IV treatment works or class II sewerage system by a backup operator with a certificate one classification lower than the facility for a period of greater than thirty consecutive days. Such requests shall be made in writing to the appropriate district office.

B. Operator of Record

The permittee shall designate one or more operator of record to oversee the technical operation of the sewerage system in accordance with paragraph (A)(2) of rule 3745-7-02 of the Ohio Administrative Code.

1. Within three days of a change in an operator of record, the permittee shall notify the Director of Ohio EPA of any such change on a form acceptable to Ohio EPA. The appropriate form can be found at the following website:

http://www.epa.ohio.gov/portals/28/documents/opcert/Operator_of_Record_Notification_Form.pdf

2. Records as required by Ohio Administrative Code 3745-7-09 shall be accessible onsite for twenty-four hour inspection, records shall be kept up to date, contain a minimum of the previous three months of data at all times, and be maintained for at least three years.

3. Each operator of record shall have a valid certification of a class equal to or greater than the classification of the treatment works as defined in Part II, Item A of this NPDES permit.

C. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
3PA00034003	Manhole on Mill Site Creek at Lincoln Way (Lat: 40N 46' 20"; Long: 80W 46' 17")
3PA00034004	Manhole at Washington and Jefferson Streets (Lat: 40N 46' 16"; Long: 80W 46' 59")
3PA00034005	Manhole at Washington and Exchange Streets (Lat: 40N 46' 16"; Long: 80W 46' 47")
3PA00034006	Manhole at S. Market St. 200' south of Washington St. (Lat: 40N 46' 14"; Long: 80W 46' 05 ")
3PA00034008	Manhole at Green Street and Riverview Dr. (Lat: 40N 46' 22"; Long: 80W 46' 22")
3PA00034009	Manhole at Maple St. 100' east of Graham St. (Lat: 40N 46' 12"; Long: 80W 46' 17")
3PA00034011	Manole 40 feet northwest of SR 164 pump station (Lat: 40N 46' 07"; Long: 80W 46' 29")
3PA00034012	Manhole 250 feet west of main lift station on main interceptor (Lat: 40N 46' 18"; Long: 80W 46' 15")

D. The permittee shall maintain in good working order and operate as efficiently as possible the "sewerage system" as defined in ORC 6111.01 to achieve compliance with the terms and conditions of this permit and to prevent discharges to the waters of the state, surface of the ground, basements, homes, buildings, etc.

E. Combined Sewer Overflow (CSO) Monitoring Requirements

1. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.
2. The permittee shall monitor the combined sewer overflows at stations 3PA00034003 through 3PA00034012 and report to Ohio EPA in accordance with the provisions of Part I.B of this permit. The permittee shall set up a rotating schedule to sample total suspended solids, CBOD5 and volume at three (3) stations during each storm event. All of the combined sewer overflows should be evaluated for activation by the monitoring sensors during each storm event.
3. In order to more accurately collect data for the volume and number of occurrence(s) per month, the permittee shall install a portable flow or level sensor at a combined sewer overflow when it is monitored in accordance with the rotating schedule set up with respect to Part II, Item E.2. Installation and use of monitoring sensor(s) shall occur no later than 2 months from the effective date of this permit. A device shall be installed at all overflow points to identify occurrences within 1 month of the effective date of this permit.

F. Water quality based permit limitations in this permit may be revised based on updated wasteload allocations or use designation rules. This permit may be modified, or revoked and reissued, to include new water quality based effluent limits or other conditions that are necessary to comply with a revised wasteload allocation, or an approved total maximum daily loads (TMDL) report as required under Section 303 (d) of the Clean Water Act.

G. Outfall Signage

The permittee shall maintain a permanent marker on the stream bank at each outfall that is regulated under this NPDES permit where a marker does not currently exist. This includes final outfalls, bypasses, and combined sewer overflows. The marker shall consist at a minimum of the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The marker shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall not be obstructed such that persons in boats or persons swimming on the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water. When an existing marker is replaced or reset, the new marker shall comply with the requirements of this section.

PART III - GENERAL CONDITIONS

1. DEFINITIONS

"Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

"Average weekly" discharge limitation means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. Each of the following 7-day periods is defined as a calendar week: Week 1 is Days 1 - 7 of the month; Week 2 is Days 8 - 14; Week 3 is Days 15 - 21; and Week 4 is Days 22 - 28. If the "daily discharge" on days 29, 30 or 31 exceeds the "average weekly" discharge limitation, Ohio EPA may elect to evaluate the last 7 days of the month as Week 4 instead of Days 22 - 28. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"Average monthly" discharge limitation means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"85 percent removal" means the arithmetic mean of the values for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

"Absolute Limitations" Compliance with limitations having descriptions of "shall not be less than," "not greater than," "shall not exceed," "minimum," or "maximum" shall be determined from any single value for effluent samples and/or measurements collected.

"Net concentration" shall mean the difference between the concentration of a given substance in a sample taken of the discharge and the concentration of the same substances in a sample taken at the intake which supplies water to the given process. For the purpose of this definition, samples that are taken to determine the net concentration shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"Net Load" shall mean the difference between the load of a given substance as calculated from a sample taken of the discharge and the load of the same substance in a sample taken at the intake which supplies water to given process. For purposes of this definition, samples that are taken to determine the net loading shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"MGD" means million gallons per day.

"mg/l" means milligrams per liter.

"ug/l" means micrograms per liter.

"ng/l" means nanograms per liter.

"S.U." means standard pH unit.

"kg/day" means kilograms per day.

"Reporting Code" is a five digit number used by the Ohio EPA in processing reported data. The reporting code does not imply the type of analysis used nor the sampling techniques employed.

"Quarterly (1/Quarter) sampling frequency" means the sampling shall be done in the months of March, June, August, and December, unless specifically identified otherwise in the Effluent Limitations and Monitoring Requirements table.

"Yearly (1/Year) sampling frequency" means the sampling shall be done in the month of September, unless specifically identified otherwise in the effluent limitations and monitoring requirements table.

"Semi-annual (2/Year) sampling frequency" means the sampling shall be done during the months of June and December, unless specifically identified otherwise.

"Winter" shall be considered to be the period from November 1 through April 30.

"Bypass" means the intentional diversion of waste streams from any portion of the treatment facility.

"Summer" shall be considered to be the period from May 1 through October 31.

"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

"Sewage sludge" means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works as defined in section 6111.01 of the Revised Code. "Sewage sludge" includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator, grit and screenings generated during preliminary treatment of domestic sewage in a treatment works, animal manure, residue generated during treatment of animal manure, or domestic septage.

"Sewage sludge weight" means the weight of sewage sludge, in dry U.S. tons, including admixtures such as liming materials or bulking agents. Monitoring frequencies for sewage sludge parameters are based on the reported sludge weight generated in a calendar year (use the most recent calendar year data when the NPDES permit is up for renewal).

"Sewage sludge fee weight" means the weight of sewage sludge, in dry U.S. tons, excluding admixtures such as liming materials or bulking agents. Annual sewage sludge fees, as per section 3745.11(Y) of the Ohio Revised Code, are based on the reported sludge fee weight for the most recent calendar year.

2. GENERAL EFFLUENT LIMITATIONS

The effluent shall, at all times, be free of substances:

- A. In amounts that will settle to form putrescent, or otherwise objectionable, sludge deposits; or that will adversely affect aquatic life or water fowl;
- B. Of an oily, greasy, or surface-active nature, and of other floating debris, in amounts that will form noticeable accumulations of scum, foam or sheen;
- C. In amounts that will alter the natural color or odor of the receiving water to such degree as to create a nuisance;
- D. In amounts that either singly or in combination with other substances are toxic to human, animal, or aquatic life;
- E. In amounts that are conducive to the growth of aquatic weeds or algae to the extent that such growths become inimical to more desirable forms of aquatic life, or create conditions that are unsightly, or constitute a nuisance in any other fashion;
- F. In amounts that will impair designated instream or downstream water uses.

3. FACILITY OPERATION AND QUALITY CONTROL

All wastewater treatment works shall be operated in a manner consistent with the following:

- A. At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with conditions of the permit.
- B. The permittee shall effectively monitor the operation and efficiency of treatment and control facilities and the quantity and quality of the treated discharge.
- C. Maintenance of wastewater treatment works that results in degradation of effluent quality shall be scheduled during non-critical water quality periods and shall be carried out in a manner approved by Ohio EPA as specified in the Paragraph in the PART III entitled, "UNAUTHORIZED DISCHARGES".

4. REPORTING

A. Monitoring data required by this permit shall be submitted monthly on Ohio EPA 4500 Discharge Monitoring Report (DMR) forms using the electronic DMR (e-DMR) internet application. e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. e-DMR information is found on the following web page:

<http://www.epa.ohio.gov/dsw/edmr/eDMR.aspx>

Alternatively, if you are unable to use e-DMR due to a demonstrated hardship, monitoring data may be submitted on paper DMR forms provided by Ohio EPA. Monitoring data shall be typed on the forms. Please contact Ohio EPA, Division of Surface Water at (614) 644-2050 if you wish to receive paper DMR forms.

B. DMRs shall be signed by a facility's Responsible Official or a Delegated Responsible Official (i.e. a person delegated by the Responsible Official). The Responsible Official of a facility is defined as:

1. For corporations - a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or the manager of one or more manufacturing, production or operating facilities, provided the manager is authorized to make management decisions which govern the operation of the regulated facility including having explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;
2. For partnerships - a general partner;
3. For a sole proprietorship - the proprietor; or,
4. For a municipality, state or other public facility - a principal executive officer, a ranking elected official or other duly authorized employee.

For e-DMR, the person signing and submitting the DMR will need to obtain an eBusiness Center account and Personal Identification Number (PIN). Additionally, Delegated Responsible Officials must be delegated by the Responsible Official, either on-line using the eBusiness Center's delegation function, or on a paper delegation form provided by Ohio EPA. For more information on the PIN and delegation processes, please view the following web page:

<http://epa.ohio.gov/dsw/edmr/eDMR.aspx>

C. DMRs submitted using e-DMR shall be submitted to Ohio EPA by the 20th day of the month following the month-of-interest. DMRs submitted on paper must include the original signed DMR form and shall be mailed to Ohio EPA at the following address so that they are received no later than the 15th day of the month following the month-of-interest:

Ohio Environmental Protection Agency
Lazarus Government Center
Division of Surface Water - PCU
P.O. Box 1049
Columbus, Ohio 43216-1049

D. Regardless of the submission method, a paper copy of the submitted Ohio EPA 4500 DMR shall be maintained onsite for records retention purposes (see Section 7. RECORDS RETENTION). For e-DMR users, view and print the DMR from the Submission Report Information page after each original or revised DMR is submitted. For submittals on paper, make a copy of the completed paper form after it is signed by a Responsible Official or a Delegated Responsible Official.

E. If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified in Section 5. SAMPLING AND ANALYTICAL METHODS, the results of such monitoring shall be included in the calculation and reporting of the values required in the reports specified above.

F. Analyses of pollutants not required by this permit, except as noted in the preceding paragraph, shall not be reported to the Ohio EPA, but records shall be retained as specified in Section 7. RECORDS RETENTION.

5. SAMPLING AND ANALYTICAL METHOD

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored flow. Test procedures for the analysis of pollutants shall conform to regulation 40 CFR 136, "Test Procedures For The Analysis of Pollutants" unless other test procedures have been specified in this permit. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to insure accuracy of measurements.

6. RECORDING OF RESULTS

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- A. The exact place and date of sampling; (time of sampling not required on EPA 4500)
- B. The person(s) who performed the sampling or measurements;
- C. The date the analyses were performed on those samples;
- D. The person(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The results of all analyses and measurements.

7. RECORDS RETENTION

The permittee shall retain all of the following records for the wastewater treatment works for a minimum of three years except those records that pertain to sewage sludge disposal, use, storage, or treatment, which shall be kept for a minimum of five years, including:

- A. All sampling and analytical records (including internal sampling data not reported);
- B. All original recordings for any continuous monitoring instrumentation;
- C. All instrumentation, calibration and maintenance records;
- D. All plant operation and maintenance records;
- E. All reports required by this permit; and
- F. Records of all data used to complete the application for this permit for a period of at least three years, or five years for sewage sludge, from the date of the sample, measurement, report, or application.

These periods will be extended during the course of any unresolved litigation, or when requested by the Regional Administrator or the Ohio EPA. The three year period, or five year period for sewage sludge, for retention of records shall start from the date of sample, measurement, report, or application.

8. AVAILABILITY OF REPORTS

Except for data determined by the Ohio EPA to be entitled to confidential status, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the appropriate district offices of the Ohio EPA. Both the Clean Water Act and Section 6111.05 Ohio Revised Code state that effluent data and receiving water quality data shall not be considered confidential.

9. DUTY TO PROVIDE INFORMATION

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

10. RIGHT OF ENTRY

The permittee shall allow the Director or an authorized representative upon presentation of credentials and other documents as may be required by law to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

11. UNAUTHORIZED DISCHARGES

A. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 11.B and 11.C.

B. Notice

1. Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

2. Unanticipated Bypass - The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.B (24 hour notice).

C. Prohibition of Bypass

1. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- c. The permittee submitted notices as required under paragraph 11.B.

2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 11.C.1.

12. NONCOMPLIANCE NOTIFICATION

A. Exceedance of a Daily Maximum Discharge Limit

1. The permittee shall report noncompliance that is the result of any violation of a daily maximum discharge limit for any of the pollutants listed by the Director in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

<http://epa.ohio.gov/dsw/permits/individuals.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The limit(s) that has been exceeded;
- c. The extent of the exceedance(s);
- d. The cause of the exceedance(s);
- e. The period of the exceedance(s) including exact dates and times;
- f. If uncorrected, the anticipated time the exceedance(s) is expected to continue; and,
- g. Steps taken to reduce, eliminate or prevent occurrence of the exceedance(s).

B. Other Permit Violations

1. The permittee shall report noncompliance that is the result of any unanticipated bypass resulting in an exceedance of any effluent limit in the permit or any upset resulting in an exceedance of any effluent limit in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site:

<http://www.epa.ohio.gov/dsw/permits/permits.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
 - b. The time(s) at which the discharge occurred, and was discovered;
 - c. The approximate amount and the characteristics of the discharge;
 - d. The stream(s) affected by the discharge;
 - e. The circumstances which created the discharge;
 - f. The name and telephone number of the person(s) who have knowledge of these circumstances;
 - g. What remedial steps are being taken; and,
 - h. The name and telephone number of the person(s) responsible for such remedial steps.
2. The permittee shall report noncompliance that is the result of any spill or discharge which may endanger human health or the environment within thirty (30) minutes of discovery by calling the 24-Hour Emergency Hotline toll-free at (800) 282-9378. The permittee shall also report the spill or discharge by e-mail or telephone within twenty-four (24) hours of discovery in accordance with B.1 above.
- C. When the telephone option is used for the noncompliance reports required by A and B, the permittee shall submit to the appropriate Ohio EPA district office a confirmation letter and a completed noncompliance report within five (5) days of the discovery of the noncompliance. This follow up report is not necessary for the e-mail option which already includes a completed noncompliance report.
- D. If the permittee is unable to meet any date for achieving an event, as specified in a schedule of compliance in their permit, the permittee shall submit a written report to the appropriate Ohio EPA district office within fourteen (14) days of becoming aware of such a situation. The report shall include the following:
1. The compliance event which has been or will be violated;
 2. The cause of the violation;
 3. The remedial action being taken;
 4. The probable date by which compliance will occur; and,
 5. The probability of complying with subsequent and final events as scheduled.
- E. The permittee shall report all other instances of permit noncompliance not reported under paragraphs A or B of this section on their monthly DMR submission. The DMR shall contain comments that include the information listed in paragraphs A or B as appropriate.
- F. If the permittee becomes aware that it failed to submit an application, or submitted incorrect information in an application or in any report to the director, it shall promptly submit such facts or information.

13. RESERVED

14. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

15. AUTHORIZED DISCHARGES

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than, or at a level in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such violations may result in the imposition of civil and/or criminal penalties as provided for in Section 309 of the Act and Ohio Revised Code Sections 6111.09 and 6111.99.

16. DISCHARGE CHANGES

The following changes must be reported to the appropriate Ohio EPA district office as soon as practicable:

A. For all treatment works, any significant change in character of the discharge which the permittee knows or has reason to believe has occurred or will occur which would constitute cause for modification or revocation and reissuance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. Notification of permit changes or anticipated noncompliance does not stay any permit condition.

B. For publicly owned treatment works:

1. Any proposed plant modification, addition, and/or expansion that will change the capacity or efficiency of the plant;
2. The addition of any new significant industrial discharge; and
3. Changes in the quantity or quality of the wastes from existing tributary industrial discharges which will result in significant new or increased discharges of pollutants.

C. For non-publicly owned treatment works, any proposed facility expansions, production increases, or process modifications, which will result in new, different, or increased discharges of pollutants.

Following this notice, modifications to the permit may be made to reflect any necessary changes in permit conditions, including any necessary effluent limitations for any pollutants not identified and limited herein. A determination will also be made as to whether a National Environmental Policy Act (NEPA) review will be required. Sections 6111.44 and 6111.45, Ohio Revised Code, require that plans for treatment works or improvements to such works be approved by the Director of the Ohio EPA prior to initiation of construction.

D. In addition to the reporting requirements under 40 CFR 122.41(l) and per 40 CFR 122.42(a), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit. If that discharge will exceed the highest of the "notification levels" specified in 40 CFR Sections 122.42(a)(1)(i) through 122.42(a)(1)(iv).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" specified in 122.42(a)(2)(i) through 122.42(a)(2)(iv).

17. TOXIC POLLUTANTS

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement. Following establishment of such standards or prohibitions, the Director shall modify this permit and so notify the permittee.

18. PERMIT MODIFICATION OR REVOCATION

A. After notice and opportunity for a hearing, this permit may be modified or revoked, by the Ohio EPA, in whole or in part during its term for cause including, but not limited to, the following:

1. Violation of any terms or conditions of this permit;
2. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
3. Change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.

B. Pursuant to rule 3745-33-04, Ohio Administrative Code, the permittee may at any time apply to the Ohio EPA for modification of any part of this permit. The filing of a request by the permittee for a permit modification or revocation does not stay any permit condition. The application for modification should be received by the appropriate Ohio EPA district office at least ninety days before the date on which it is desired that the modification become effective. The application shall be made only on forms approved by the Ohio EPA.

19. TRANSFER OF OWNERSHIP OR CONTROL

This permit may be transferred or assigned and a new owner or successor can be authorized to discharge from this facility, provided the following requirements are met:

A. The permittee shall notify the succeeding owner or successor of the existence of this permit by a letter, a copy of which shall be forwarded to the appropriate Ohio EPA district office. The copy of that letter will serve as the permittee's notice to the Director of the proposed transfer. The copy of that letter shall be received by the appropriate Ohio EPA district office sixty (60) days prior to the proposed date of transfer;

B. A written agreement containing a specific date for transfer of permit responsibility and coverage between the current and new permittee (including acknowledgement that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on) shall be submitted to the appropriate Ohio EPA district office within sixty days after receipt by the district office of the copy of the letter from the permittee to the succeeding owner;

At anytime during the sixty (60) day period between notification of the proposed transfer and the effective date of the transfer, the Director may prevent the transfer if he concludes that such transfer will jeopardize compliance with the terms and conditions of the permit. If the Director does not prevent transfer, he will modify the permit to reflect the new owner.

20. OIL AND HAZARDOUS SUBSTANCE LIABILITY

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

21. SOLIDS DISPOSAL

Collected grit and screenings, and other solids other than sewage sludge, shall be disposed of in such a manner as to prevent entry of those wastes into waters of the state, and in accordance with all applicable laws and rules.

22. CONSTRUCTION AFFECTING NAVIGABLE WATERS

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

23. CIVIL AND CRIMINAL LIABILITY

Except as exempted in the permit conditions on UNAUTHORIZED DISCHARGES or UPSETS, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

24. STATE LAWS AND REGULATIONS

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

25. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

26. UPSET

The provisions of 40 CFR Section 122.41(n), relating to "Upset," are specifically incorporated herein by reference in their entirety. For definition of "upset," see Part III, Paragraph 1, DEFINITIONS.

27. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

28. SIGNATORY REQUIREMENTS

All applications submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR 122.22.

All reports submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR Section 122.22.

29. OTHER INFORMATION

A. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

B. ORC 6111.99 provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

C. ORC 6111.99 states that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

D. ORC 6111.99 provides that any person who violates Sections 6111.04, 6111.042, 6111.05, or division (A) of Section 6111.07 of the Revised Code shall be fined not more than \$25,000 or imprisoned not more than one year, or both.

30. NEED TO HALT OR REDUCE ACTIVITY

40 CFR 122.41(c) states that it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with conditions of this permit.

31. APPLICABLE FEDERAL RULES

All references to 40 CFR in this permit mean the version of 40 CFR which is effective as of the effective date of this permit.

32. AVAILABILITY OF PUBLIC SEWERS

Notwithstanding the issuance or non-issuance of an NPDES permit to a semi-public disposal system, whenever the sewage system of a publicly owned treatment works becomes available and accessible, the permittee operating any semi-public disposal system shall abandon the semi-public disposal system and connect it into the publicly owned treatment works.