

Application No. OHP000110

Issue Date: August 24, 2007

Effective Date: October 1, 2007

Expiration Date: September 30, 2012

Ohio Environmental Protection Agency

Indirect Discharge Permit

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as "the Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code 6111),

National Fruit & Vegetable Technology Corporation

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge wastewater from its facility located at 210 Water Street, Baltimore, Ohio 43105, Fairfield County

into the Publicly Owned Treatment Works of the Village of Baltimore located at 2005 Basil-Western Road, Baltimore, Ohio 43105

in accordance with the conditions specified in Parts I, II, and III of this permit.

The permit is issued to apply and enforce pretreatment rules of the state of Ohio. The rights granted by this permit shall not supersede the primacy of the above authority in the regulation of its publicly owned treatment works.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

---

Chris Korleski  
Director

Total Pages: 10

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 4DP00010001.

Table - End of Pipe - 001 - Final

Effluent Characteristic  Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00056 - Flow Rate - GPD	-	-	-	-	-	-	-	1/Month	24hr Total	All
00310 - Biochemical Oxygen Demand, 5 Day - mg/l	-	-	-	-	-	-	-	1/Month	Composite	All
00335 - Chemical Oxygen Demand (Low Level) - mg/l	-	-	-	-	-	-	-	1/Month	Composite	All
00402 - pH, Minimum - S.U.	-	5.0	-	-	-	-	-	1/Month	Grab	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Composite	All

2. Samples shall be collected from the catch basin following the potato processing pretreatment unit prior to connecting with the village sewer.

## Part II, Other Requirements

1. The permittee shall comply with all applicable rules, regulations, and ordinances of the Village of Baltimore. If the authority to discharge is revoked by the POTW, this shall also be considered grounds for revocation of this permit.

2. In addition to the report submitted to Ohio EPA under Part III, Item 3, of this permit, a copy of each discharge monitoring report shall be submitted to the POTW at the following address:

Village of Baltimore  
Wastewater Treatment Plant  
Attn: Village Administrator  
103 West Market Street  
Baltimore, Ohio 43105

3. Any slug loading shall be reported to the POTW at (614) 862-8015 pursuant to requirements in Part III, Item 10.